



WHITE—DIVISION OF WATER RESOURCES  
 PRIMARY—CLIENT'S COPY  
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

OFFICE USE ONLY  
 Log No. **48073**  
 Permit No. \_\_\_\_\_  
 Basin. **212**

NOTICE OF INTENT NO. **14436**

1. OWNER **USPCI/LAIDLAW** ADDRESS AT WELL LOCATION **FORMER UPRR YARD**  
 MAILING ADDRESS **3538 RAYMERT DR #3 LAS VEGAS NV 89121**  
 2. LOCATION **SE 1/4 SW 27 T. 20 N. R. 61 E CLARK** County  
 PERMIT NO. **MO-2587** Issued by Water Resources Parcel No. **71-14** Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE **MW-57A**  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **AUGER**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<b>SANDY GRAVEL</b>		<b>0</b>	<b>8</b>	<b>8</b>
<b>SILTY CLAY</b>		<b>8</b>	<b>12</b>	<b>4</b>
<b>CALICHE</b>		<b>12</b>	<b>13.5</b>	<b>1.5</b>
<b>SILT</b>		<b>13.5</b>	<b>15</b>	<b>1.5</b>
<b>CALICHE</b>		<b>15</b>	<b>16</b>	<b>1</b>
<b>SILT</b>		<b>16</b>	<b>19</b>	<b>3</b>
<b>CALICHE</b>		<b>19</b>	<b>21</b>	<b>2</b>
<b>CLAYEY SAND</b>		<b>21</b>	<b>27</b>	<b>6</b>
<b>SANDY CLAY</b>		<b>27</b>	<b>31</b>	<b>4</b>

8. WELL CONSTRUCTION  
 Depth Drilled **31** Feet Depth Cased **31** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From **8** Inches To **31** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>2.375</b>	<b>0.64</b>	<b>0.154</b>	<b>0</b>	<b>31</b>

Perforations:  
 Type perforation **FACTORY SLOT**  
 Size perforation **0.010**  
 From **21** feet to **31** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **0-18' / 18-20' BENTONITE**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **20** feet to **31** feet

9. WATER LEVEL  
 Static water level **17.29** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started **JUNE 15** 19**95**  
 Date completed **JUNE 15** 19**95**

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **THOMAS HIGH** Contractor  
 Address **4670 SO COLARIS AVE LAS VEGAS NV 89103** Contractor  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **M1869**  
 Signed **Thomas H. High**  
 By driller performing actual drilling on site or contractor  
 Date **7-21-95**

