WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48094
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 28648 28647

1. OWNER Mike Casey
MAILING ADDRESS 1600 Allen Road
Fallon, Nevada 89406

ADDRESS AT WELL LOCATION 14123 ~~14555~~ Carson Highway
Fallon, Nevada 89406

2. LOCATION ~~NE~~ SW ¼ ~~NW~~ SE ¼ Sec. 27 25 T 19 N/S R 26 E Churchill County
PERMIT NO. Issued by Water Resources | 07-071-60 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	15	15
Brown Clay		15	30	15
Brown Sand		30	45	15
Brown Clay		45	75	30
Brown Sand		75	85	10
Brown Clay		85	145	60
Brown Sand		145	155	10
Brown Clay		155	175	20
Brown Sand	XX	175	190	15
Brown Clay		190	194	4

Date started March 27, 19 95
Date completed March 28, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 194 Feet Depth Cased 194 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	194 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	194

Perforations:
Type perforation Mill-Cut
Size perforation 1/8"
From 174 feet to 194 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50ft.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 194 feet

9. WATER LEVEL
Static water level 96 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. Contractor
Address P.O. BOX 1265 Contractor
FALLON, NEVADA 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed [signature] By driller performing actual drilling on site or contractor
Date 4-19-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627