

OFFICE USE ONLY
 Log No. 48114
 Permit No. _____
 Basin. 8-101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28840
 GREYSTONE CIR

1. OWNER Rich Lee ADDRESS AT WELL LOCATION 3475 Greystone Drive Fallon NV 89406
 MAILING ADDRESS 1380 Perazzo Ln Fallon NV 89406
 2. LOCATION SE 1/4 NW 1/4 Sec 8 T 19 N/S R 29 E Churchill County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sands		0	13	13
Brown clay		13	14	1
Brown sand		14	25	11
Grey sands		25	47	22
Black silty clay		47	67	20
white grey sands		67	73	6
Grey clay		73	75	2
Brown sands	75	75	87	12

8. WELL CONSTRUCTION
 Depth Drilled 87 Feet Depth Cased 87 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
6 1/8 Inches 50 Feet 87 Feet
10 Inches 0 Feet 50 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>120</u>	<u>18/18</u>	<u>0</u>	<u>87</u>

Perforations:
 Type perforation Factory
 Size perforation 0028 0060
 From 82 feet to 83 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 9 foot 3 inch feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 70.0 °F Quality ok

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Welso Corp. Contractor
 Address 335 N Broadway Contractor
Fallon NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
 Signed Jesus Manuccioni
 By driller performing actual drilling on site or contractor
 Date 9-17-95

Date started March 17 1995
 Date completed March 17 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>70</u>		<u>1/2</u>