

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28828

1. OWNER Alkies Const ADDRESS AT WELL LOCATION 1265 Golden Parkway
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 NE 1/4 Sec 20 T. 19 N/S R 29 E Churchill County
 PERMIT NO. _____ Parcel No. 08-322-26 Subdivision Name Neutrace
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Grey Sand	✓	0	17	17
Grey Clay		17	20	3
Grey Sand	✓	20	31	31
Black Clay		31	71	20
Grey Sand	✓	71	80	9
Brown Clay		80	82	2
Brown Sand		82	90	8

8. WELL CONSTRUCTION
 Depth Drilled 90 Feet Depth Cased 90 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
 From 6 Inches To 90 Feet
 From _____ Inches To _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>1</u>	<u>90</u>

 Perforations:
 Type perforation Machine slot
 Size perforation .070
 From _____ feet to _____ feet
 From 83 feet to 88 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet
 9. WATER LEVEL
 Static water level 9'-8" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality untested

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		<u>1</u>

 Date started Feb 23, 1995
 Date completed Feb 23, 1995

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Welsco Contractor
 Address Box 888 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 11952
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
 Signed [Signature]
 Date Feb-23