

OFFICE USE ONLY
 Log No. 48120
 Permit No. _____
 Basin 8-101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26359

1. OWNER K. Pastora ADDRESS AT WELL LOCATION 305 Hunter Parkway
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 NW 1/4 Sec 29 T. 9 N/S R. 29 E. Churchill County
 PERMIT NO. 08-313-13 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		5	10	10
Brown Clay		10	13	3
Brown Sand	L	13	27	14
Grey Sand	L	27	31	4
Grey Sandy Clay		31	51	20
Black Silty Sand	L	51	71	20
Grey Sand	AF	71	86	15
Brown Sand	L	86	95	9

8. WELL CONSTRUCTION
 Depth Drilled 95 Feet Depth Cased 95 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 53 Feet
6 Inches 50 Feet 95 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>71</u>	<u>95</u>

Perforations:
 Type perforation Machine Slot
 Size perforation .010
 From _____ feet to _____ feet
 From 88 feet to 93 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 11 3/4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 °F Quality Un-tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WELSCO CORP Contractor
 Address 335 N. BROADWAY Contractor
FALLON NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
 Signed _____ By driller performing actual drilling on site or contractor
 Date _____

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 Date started April 6 1995
 Date completed April 6 1995

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		<u>1</u>