

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24652

1. OWNER Bill Davidson ADDRESS AT WELL LOCATION Duck Creek Basin  
 MAILING ADDRESS P.O. Box 1077 East of McGill, Nevada  
McGill, NV 89318

2. LOCATION SW 1/4 SW 1/4 Sec. 20 T 19 N 65 E White Pine County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. 2 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Altered Volcanics		5	35	30
Volcanics		35	45	10
Decomposed Volcanics		45	135	90
Fractured Volcanics	x	135	190	55
Decomposed Volcanics		190	265	75
Fractured Volcanics	x	265	285	20
Decomposed Volcanics		285	290	5
Clay		290	303	13

8. WELL CONSTRUCTION  
 Depth Drilled 303 Feet Depth Cased 303 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 303 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	.188	0	303

Perforations:  
 Type perforation Factory  
 Size perforation 1/8" x 2 1/2" 6 rows  
 From 123 feet to 303 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 100  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 100 feet to 303 feet

9. WATER LEVEL  
 Static water level 57 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started September 23, 1994  
 Date completed February 19, 1995

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailor <input checked="" type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3 H.P.	20	246	2
	20	224	1

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc. Contractor  
 Address 557 Ely Avenue Contractor  
Ely, NV 89301

Nevada contractor's license number issued by the State Contractor's Board 14790  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641

Signed Jerrold D. Christiansen  
 By driller performing actual drilling on site or contractor  
 Date April 21, 1995