

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22155

1. OWNER David E. Groth ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 162 \_\_\_\_\_  
Enterprise NV  
 2. LOCATION NW 1/4 SE 1/4 Sec. 29 T. 20 N. R. 53 E. Enterprise County  
 PERMIT NO. 0738040 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Caliche		2	23	21
Granite		23	231	208
fractured Granite	X	231	273	41
Granite		273	280	7

8. WELL CONSTRUCTION  
 Depth Drilled 280 Feet Depth Cased 280 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 280 Feet  
10 Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>280</u>

Perforations:  
 Type perforation Factor 7  
 Size perforation \_\_\_\_\_  
 From 230 feet to 270 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 280 feet

9. WATER LEVEL  
 Static water level 210 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started March 26, 1995  
 Date completed March 28, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>40</u>	<u>0</u>	<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AAA Drilling Contractor  
 Address 181-14 West Bullion Contractor  
Enterprise NV  
 Nevada contractor's license number issued by the State Contractor's Board 0020684  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438  
 Signed Shaw Bennett  
 By driller performing actual drilling on site or contractor  
 Date April 1 - 95