

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26033

1. OWNER Tanya Kiehol ADDRESS AT WELL LOCATION 1720 Rolling Hills Rd., Fallon, NV 89406
 MAILING ADDRESS Same

2. LOCATION S 1/2 1/4 1/4 Sec. 33 T. 20 N/S R. 26 E. Churchill County
 PERMIT NO. NA Issued by Water Resources Parcel No. 09-271-57 Subdivision Name Rolling Hill Estates

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other (RVC)

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface Clay		0	3	3
Medium Sand	10	3	42	39
(Some Coarse Sand)				
Bank Sand (Both - Coarse & Fine)		42	63	
Medium & Fine Sands		63	77	
Coarse Sands	82	77	82	

8. WELL CONSTRUCTION
 Depth Drilled 82 Feet Depth Cased 83 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 8 1/2 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.88</u>	<u>71</u>	<u>82</u>

Perforations:
 Type perforation Trench Cut
 Size perforation 1/8 x 6" x 6 rows perf
 From 62 feet to 82 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55+ Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 55-56 feet to 82 feet

'95 MAY -2 AM 1:20
 STATE ENGINEERS OFFICE

9. WATER LEVEL
 Static water level 10' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality Good

Date started 4/18/95, 19____
 Date completed _____, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>70-75</u>		<u>4 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name John Downing Inc Contractor
 Address PO 599 Contractor
23, NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1576

Signed Janice Power
 By driller performing actual drilling on site or contractor
 Date 4/20/95