WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48150
Permit No.
Basin 612A

NOTICE OF INTENT NO. 23801

1. OWNER LOWELL & PAT CAROTHERS
MAILING ADDRESS 204 DAGGETT
Reno, NV 89511

ADDRESS AT WELL LOCATION 9540 RED ROCK RD

2. LOCATION SE ¼ SE ¼ Sec. 35 T 21 N/S R 18 E WASHOE County
PERMIT NO. [redacted] Issued by Water Resources
9004004 Parcel No.
SILVER KNOLLS Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TAN YELLOW WHITE				
BROWN DG SAND				
WITH SMALL TAN				
CLAY LAYERS		0	140	
STICKY GREEN CLAY		140	144	
	X			
144TD				

'95 MAY -5 A11:11
STATE ENGINEER

Date started 4-24, 1995
Date completed 4-25, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
6+		4

8. WELL CONSTRUCTION
Depth Drilled 144 Feet Depth Cased 144 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.96	188	+1 1/2	144

Perforations:
Type perforation FACTORY SAWED
Size perforation 3/32 x3"
From 136 feet to 126 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 104
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 144 feet to 104 feet

9. WATER LEVEL
Static water level 55' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. PUMP & WELL SERVICE INC. Contractor
Address 1800 1/2 FRAZER AVENUE Contractor
SPARKS, NV 89431

Nevada contractor's license number issued by the State Contractor's Board [redacted] 1509
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 0035387A

Signed [signature] By driller performing actual drilling on site or contractor
Date 5-3-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627