WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48434
Permit No.
Basin 176

NOTICE OF INTENT NO. 32107

1. OWNER White Shields Inc.
MAILING ADDRESS P.O. Box 477
Grandview, WA 98930

ADDRESS AT WELL LOCATION Ruby Valley Indian Allotment

2. LOCATION SW ¼ NE ¼ Sec. 6 T. 27 N/S R. 58 E. Elko County
PERMIT NO. (Issued by Water Resources) Indian land (Parcel No.) Tract of land (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 3 | 3 |
| Blue Siltstone | | 3 | 26 | 23 |
| Cement gravel | | 26 | 155 | 129 |

95 MAY -8 P2:30
STATE ENGINEER

Date started April 20, 1995
Date completed April 21, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Blow test | 150 | | 6 |
| Pump | 450 | 103 | 3 |

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10-5/8 Inches | | 0 Feet | 155 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6-5/8 | 13 | .188 | +1-1/2 | 155 |
| | | | | |

Perforations:
Type perforation Millslot
Size perforation 3/16 x 3
From 114 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 155 feet

9. WATER LEVEL
Static water level 96 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed Daniel Wenk (By driller performing actual drilling on site or contractor)
Date 4-27-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627