WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48140
Permit No.
Basin 049

NOTICE OF INTENT NO. 32134

1. OWNER Kent Immenschuh
MAILING ADDRESS P.O. Box 5817
Elko, NV 89802

ADDRESS AT WELL LOCATION E side of Indiana Ave 400' of 1st Street

2. LOCATION SE ¼ SW ¼ Sec. 7 T 34 N/S R 56 E Elko County
PERMIT NO. (Issued by Water Resources) 32-005-15 (Parcel No.) Last Chance #3 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Boulders & gravel		2	15	13
Gravel & clay		15	40	25
Brown sandy clay		40	105	65
Brown sandy clay w/small layers of pea gravel		105	270	165
Tan green white siltstone	x	270	288	18
Brown siltstone		288	360	72
Siltstone w/small cracks	x	360	370	10
Siltstone		370	400	30

Date started April 10, 19 95
Date completed April 17, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		4

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10-5/8	0	400

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1-1/2	400

Perforations:
Type perforation Mill slot
Size perforation 3/16 x 3
From 280 feet to 300 feet
From 360 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 286 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed John C. Lee (By driller performing actual drilling on site or contractor)
Date 4-19-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627