WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48143
Permit No.
Basin 344

NOTICE OF INTENT NO. 32135

1. OWNER BALDWIN ABRILLE
MAILING ADDRESS P.O. Box 2319
Elko, NV 89803

ADDRESS AT WELL LOCATION North side of South 4th between Quincy & Monroe

2. LOCATION NE ¼ SE ¼ Sec. 5 T. 35 N/S R. 57 E. Elko County
PERMIT NO. (Issued by Water Resources) 26-017-06 (Parcel No.) Twin River Ranches #4 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 2 | 2 |
| Sandy clay | | 2 | 40 | 38 |
| Yellow green siltstone | | 40 | 70 | 30 |
| Purple brown clay rock | | 70 | 105 | 35 |
| Interbedded layers of siltstone & rock | | 105 | 160 | 55 |
| Brown green rock | | 160 | 208 | 48 |
| Brown green fractured rock | X | 208 | 215 | 7 |
| Brown green rock | | 215 | 260 | 45 |
| Green black rock with some small fractures | X | 260 | 300 | 40 |

Date started April 5, 19 95
Date completed April 7, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 2 | | 4 |

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10-5/8 Inches | | 0 Feet | 300 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6-5/8 | 11 | .188 | +1-1/2 | 300 |
| | | | | |

Perforations:
Type perforation Mill slot
Size perforation 3/16 x 3
From 200 feet to 220 feet
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1654
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-12-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627