

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **25439**

1. OWNER **Travis Terras** ADDRESS AT WELL LOCATION **#8 PENOLA Rd**  
 MAILING ADDRESS **P.O. Box 1451** **Round Mountain NV 8945**  
 2. LOCATION **SE 1/4 NW 1/4 Sec 29 T. 11 N. R. 43 E. Nye County**  
 PERMIT NO. **10-371-13** Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
fluv.		0	5	
Brn clay		5	13	
green clay		13	18	
gravel		18	40	
Brn clay		40	53	
yellow/Brn clay		53	65	
small gravel	Tr	65	74	
grey clay		74	80	
Large gravel	Art. flow	80	112	32
Brn clay		112	130	
Large gravel		130	140	10
Blue/green clay		140	150	

8. WELL CONSTRUCTION  
 Depth Drilled **150** Feet Depth Cased **150** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From **12 1/4** Inches To **6** Feet **150** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>12.51</b>	<b>.185</b>	<b>+2</b>	<b>150</b>

Perforations:  
 Type perforation **Milled slot**  
 Size perforation **1/8 x 3 x 69**  
 From **50** feet to **110** feet  
 From **130** feet to **140** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50'**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level **ARTESIAN** feet below land surface  
 Artesian flow **20** G.P.M. P.S.I.  
 Water temperature **60** °F Quality **good**

Date started **4-15**, 19**95**  
 Date completed **4-18**, 19**95**

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<b>Very good well -</b>			
<b>Potential</b>	<b>152 gpm</b>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Weyerer Drilling Co.** Contractor  
 Address **2220 Stowe Dr.** Contractor  
**RENO NV 89511**  
 Nevada contractor's license number **024521**  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1442**  
 Signed **Las Weyerer**  
 By driller performing actual drilling on site or contractor  
 Date **4-19-95**