WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48155
Permit No.
Basin 048

NOTICE OF INTENT NO. 32108

1. OWNER Robert King
MAILING ADDRESS 831 Spring Valley PKWY
Elko, NV 89801

ADDRESS AT WELL LOCATION N. side of McLelland Ave Between 14th & 15th

2. LOCATION NW ¼ SE ¼ Sec 17 T 32 N/S R 55 E Elko County
PERMIT NO. (Issued by Water Resources) 28-008-19 (Parcel No.) Lucky Nugget #2 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Clay & Rock		3	12	9
Brown-Red Sandstone		12	195	183
White Sandstone		195	250	55
Brown Sandstone		250	350	100
White Sandstone		350	440	90

'95 APR 20 AM 8:58 STATE ENGINEER

Date started 4-3, 1995
Date completed 4-4, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		4

8. WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 440 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches	0 Feet	440 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1½	440

Perforations:
Type perforation Millslot
Size perforation 3/16 X 3
From feet to feet
From 420 feet to 440 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 440 feet

9. WATER LEVEL
Static water level 330 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-10-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627