

OFFICE USE ONLY  
 Log No. 48157  
 Permit No. \_\_\_\_\_  
 Basin. 049

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25827

1. OWNER Bill A. CRANE ADDRESS AT WELL LOCATION West End of Elko Summit Dr North side lot 9c  
 MAILING ADDRESS 19 W HANNAH Blvd SAGINAW MI

2. LOCATION SW 1/4 SW 1/4 Sec 25 T. 34 N/S R. 55 E Elko County Elko  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name Elko Summit ESTATES

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sud soil		0	14	14
White SANDSTONE		14	116	102
lose SANDSTONE	K	116	124	8
White SANDSTONE		124	183	61
CLAY		183	210	33
White SANDSTONE		210	235	25
lose SANDSTONE	K	235	250	15
CLAY		250	270	20
Rock		270	271	1
CLAY		271	285	14

8. WELL CONSTRUCTION

Depth Drilled 285 Feet Depth Cased 285 Feet

HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 285 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>188</u>	<u>+1</u>	<u>285</u>

Perforations:  
 Type perforation slots  
 Size perforation 3/4 x 3"  
 From 100 feet to 120 feet  
 From 260 feet to 280 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 52 feet to 285 feet

Date started 11-14 1994  
 Date completed 4-6 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>10</u>	<u>120</u>	<u>10</u>

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FERTIG Drilling Co Contractor  
 Address PO BOX 525 Contractor  
Elko NV 89801  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Shouk J. J. J.  
 By driller performing actual drilling on site or contractor  
 Date 4-6-95