

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 28865
 6 miles north of Ely

1. OWNER Rita Wilson ADDRESS AT WELL LOCATION 6 miles north of Ely
 MAILING ADDRESS General Delivery
Ely, Nv 89301
 2. LOCATION NE 1/4 SW 1/4 Sec. 22 T. 17 N. R. 63 E. White Pine County
 PERMIT NO. 151 Cross Timbers
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Sand and Gravel		5	20	15
Clay and Small Gravel		20	40	20
Clay and Gravel		40	55	15
Clay and Big Gravel		55	60	5
Clay		60	65	5
Clay and Gravel		65	75	10
Clay		75	80	5
Clay and Gravel		80	100	20
Sandy Clay		100	110	10
Clay and Gravel	x	110	115	5
Clay		115	135	20
Water Bearing Gravel	x	135	140	5
Clay and Gravel		140	160	20
Clay		160	170	10
Clay and Gravel		170	175	5
Water Bearing Gravel	x	175	185	10

8. WELL CONSTRUCTION
 Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10</u> Inches	<u>0</u> Feet <u>185</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>0</u>	<u>185</u>

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 rows
 From 85 feet to 185 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 185 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc.
 Contractor
557 Ely Avenue
 Address Ely, NV 89301
 Contractor
 Nevada contractor's license number 14790
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 641
 Division of Water Resources, the on-site driller:
 Signed Jerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date August 14, 1995

Date started July 17, 19 95
 Date completed July 20, 19 95

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>40</u>	<u>100</u>	<u>1</u>	

RECEIVED
 95 AUG 22 AM 10:58
 STATE ENGINEERS OFFICE