WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48172
Permit No.
Basin 8-1

NOTICE OF INTENT NO. 32989

1. OWNER Michael Casey
MAILING ADDRESS 1550 Allen Rd.
Fallon, NV. 89406

ADDRESS AT WELL LOCATION 14500 Carson Hwy
Fallon, NV. 89406

2. LOCATION ~~NE~~ SW ¼ ~~NW~~ SE ¼ Sec. 25 ~~27~~ T 19 N/S R 26 E Churchill County

PERMIT NO. (Issued by Water Resources) | 007-071-52 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	15	15
Sand		15	35	20
Gravel		35	50	15
Brown Clay		50	60	10
Sand		60	73	13
Brown Clay		73	90	17
Sand		90	100	10
Brown Clay		100	107	7
Sand		107	150	43
Brown Clay		150	160	10
Grayish Brown Clay		160	171	11
Gray Clay		171	205	35
Gray Sand	XX	205	215	10

Date started June 16, 19 95
Date completed June 16, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 215 Feet Depth Cased 215 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	215 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	215

Perforations:
Type perforation Mill-Cut
Size perforation 1/8"
From 195 feet to 215 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100ft.
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
XX Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 215 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NV. 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources to the on-site driller 1753

Signed Wayne Parsons (By driller performing actual drilling on site or contractor)

Date 7/17/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627