

OFFICE USE ONLY  
 Log No. 48174  
 Permit No. \_\_\_\_\_  
 Basin. \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26769

1. OWNER [Signature] ADDRESS AT WELL LOCATION 2970  
 MAILING ADDRESS 599 Paul Brady St  
SS. NV 89428  
 2. LOCATION 1/4 25 1/4 Sec. 20 T. 17 N/S R. 25 County  
 PERMIT NO. 17-481-09 Parcel No. 200000 3000 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>28</u>	<u>28</u>
<u>Sand, Clay</u>		<u>28</u>	<u>61</u>	<u>33</u>
<u>Clay</u>		<u>61</u>	<u>93</u>	<u>32</u>
<u>Sand, Clay</u>	<u>112</u>	<u>93</u>	<u>112</u>	<u>19</u>
<u>Sand, Gravel &amp; Fine</u>	<u>139</u>	<u>112</u>	<u>139</u>	<u>26</u>

'95 JUL 24 P.2:26  
 STATE ENGINEERS INC.

8. WELL CONSTRUCTION  
 Depth Drilled 139 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 139 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.38</u>	<u>1</u>	<u>139</u>

Perforations:  
 Type perforation Iron Pipe  
 Size perforation 3 1/2 x 6 x 6 RODLESS PERS  
 From 134 feet to 139 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 139 feet

9. WATER LEVEL  
 Static water level 36 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature C °F Quality Good

Date started 6/22/95, 19\_\_\_\_\_  
 Date completed 6/23/95, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25-60</u>	<u>6</u>	<u>1:00</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Paul Brady Drilling Inc Contractor  
 Address 20 599 Contractor  
SS. NV 89428  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1874  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 7/6/95