WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48175
Permit No.
Basin

NOTICE OF INTENT NO. 32556

1. OWNER PAUL ROMERO
MAILING ADDRESS 46 Martin Street
Reno, NV 89509

ADDRESS AT WELL LOCATION
11580 Chesapeak
Reno, NV 89506

2. LOCATION SE ¼ SW ¼ Sec. 15 T 21N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 080-332-15 (Parcel No.) Lemmon VAlely (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	18	17
Brown sandy clay		18	46	28
Brown clay		46	88	42
Med. coarse sands		88	93	5
Brown sandy clays		93	123	30
Soft zone	X	123	131	8
Brown clay		131	136	5
Soft zone, brown sand	X	136	145	9
Soft brown clay		145	146	1

Date started 7-24-95, 19
Date completed 7-25-95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		

8. WELL CONSTRUCTION
Depth Drilled 146 Feet Depth Cased 146 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	146	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	146

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 146 feet

9. WATER LEVEL
Static water level 81 feet below land surface
Artesian flow G.P.M. 10 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date July 26, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627