

OFFICE USE ONLY
 Log No. 48176
 Permit No. 08
 Basin. 08

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32552

1. OWNER Bob Mikulski ADDRESS AT WELL LOCATION Cabrillo Lane
 MAILING ADDRESS 1770 Geary St Sparks, Nevada 89436
Reno, Nevada 89503
 2. LOCATION NW 1/4 NW 1/4 Sec 2 T. 21 N N/S R. 20 E. Washoe County
 PERMIT NO. 076-282-03 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	1	1
Brown Sandy clay with boulders		1	3	2
D.G. Boulder		3	6	3
Smaller Boulders & gravel with brown clay		6	61	55
Brown Sandy clay		61	88	27
Light Brown volcanic rock with clay streaks.		88	111	23
Soft Zone (no water)		111	112	1
Light brown volcanic rock with clay streaks		112	156	44
Dark brown volcanic some clay		156	206	50
Brown clay		206	210	4
Green clay		210	232	22
Brown clay		232	245	13
Dark brown clay		245	252	7
Green sandy clay		252	283	31
Gray clay		283	294	19
Green Clay		294	388	94
Gray Granite		388	470	82
Fracture Granite		470	527	57
Gray Granite		527	540	514

8. WELL CONSTRUCTION
 Depth Drilled 540 Feet Depth Cased 540 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 50 Feet
8 5/8 Inches 50 Feet 540 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	540

Perforations:
 Type perforation Factory Sawn Slot
 Size perforation 3/32 x 3 x 5 around
 From 460 feet to 500 feet
 From 515 feet to 535 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 540 feet

9. WATER LEVEL
 Static water level 400 feet below land surface
 Artesian flow _____ G.P.M. 7 1/2 P.S.I.
 Water temperature cold _____ °F Quality clear

Date started 7-17-95, 19____
 Date completed 7-20-95, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>7 1/2</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89511
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date July 25, 1995