WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48193
Permit No.
Basin 162

NOTICE OF INTENT NO. 14226

1. OWNER Allan Meyer
MAILING ADDRESS 323 W. St. Louis
Pahrump NV 89060

ADDRESS AT WELL LOCATION 651 Dyer Rd
Pahrump

2. LOCATION NE ¼ NE ¼ Sec 12 T 20 N/S R 52 E Nye County
PERMIT NO. 96-702-01 Issued by Water Resources
Parcel No.
Subdivision Name Charleston Park Ranchos

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay	TD	0	100	100

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 101 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
15 3/4 Inches	0 Feet	100 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	19	188	0	101

Perforations:
Type perforation Factory
Size perforation 1/4 x 4"
From 50 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 65 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce Robinson Contractor
Address PO Box 307 Contractor
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 15972
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 944
Signed [signature] By driller performing actual drilling on site or contractor
Date 8-2-95

Date started 7-14, 1995
Date completed 7-21, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
700	10	3.0

CONFIDENTIAL
Received
AUG 8 1995
LAS VEGAS OFFICE

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627