WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48212
Permit No.
Basin 048

NOTICE OF INTENT NO. 32115

1. OWNER Frank Demaline
MAILING ADDRESS 536 W. Belloak
Elko, NV 89801

ADDRESS AT WELL LOCATION Pioneer Way

2. LOCATION NE ¼ SE ¼ Sec. 15 T. 33 ☐N ☒S R. 55 E. Elko County
PERMIT NO. (Issued by Water Resources) 77-003-08 (Parcel No.) Western Hills (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top soil | | 0 | 3 | 3 |
| Brown siltstone | | 3 | 45 | 42 |
| Brown sandstone | | 45 | 120 | 75 |
| Hard silicified material | x | 120 | 260 | 140 |

Date started 6-9, 19 95
Date completed 6-10, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 60 | | 3 |

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 260 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +1½ | 260 |
| | | | | |

Perforations:
Type perforation Millslot
Size perforation 3/16 X 3
From feet to feet
From 240 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed Dave Bensh (By driller performing actual drilling on site or contractor)
Date 7-3-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627