WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48219
Permit No.
Basin 047

NOTICE OF INTENT NO. 30005

1. OWNER Reed Ranching
MAILING ADDRESS Jiggs, NV 89827
ADDRESS AT WELL LOCATION Reed Ranch near Jiggs, Nevada

2. LOCATION NE ¼ SE ¼ Sec. 33 T. 31 N/S R. 56 E. Elko County
PERMIT NO. 60657 (Issued by Water Resources) Parcel No. Tract of Land (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	16	16
Brown Siltstone		16	19	3
Silty Gravel	X	19	58	39
Brown Siltstone		58	75	17
Med. gravel & Sand	X	75	103	28
Course gravel/sand	X	103	140	37

RECEIVED 95 AUG 17 AM 10:38 STATE ENGINEER'S OFFICE

Date started August 3, 1995
Date completed August 7, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow test	130+		3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12-3/4 Inches	0 Feet	23 Feet
10-5/8 Inches	23 Feet	140 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1-1/2	140

Perforations:
Type perforation Mill Slot
Size perforation 3/16 x 3 x 6 rows
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [X] Poured
Seal Type: [X] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P. O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed John C. Sim (By driller performing actual drilling on site or contractor)
Date 8-15-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627