

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26732

1. OWNER Bill Betts Jr ADDRESS AT WELL LOCATION Shen & Deader
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 NW 1/4 Sec 1 T 17 N/S R 24 E County _____
 PERMIT NO. 17-023-20 Parcel No. _____
 Issued by Water Resources _____ Subdivision Name Mountain View Sub

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand, Clay</u>		<u>0</u>	<u>5</u>	<u>5'</u>
<u>Sand Gravel</u>		<u>5</u>	<u>25</u>	<u>20'</u>
<u>Coarse Sand</u>		<u>25</u>	<u>36</u>	<u>11'</u>
<u>Sand, Gravel, Clay</u>	<u>95</u>	<u>61</u>	<u>95</u>	<u>34'</u>
<u>Sand Gravel</u>	<u>120</u>	<u>95</u>	<u>120</u>	<u>25'</u>

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 121 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 100 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13</u>	<u>1 3/8</u>	<u>71</u>	<u>120</u>

Perforations:
 Type perforation Taper Split
 Size perforation 3/4" max 8' x 6" # narrow part
 From 112 feet to 120 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 58' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 58' feet to 120' feet

RECEIVED
 95 AUG 17 PM 2:37
 STATE ENGINEERS OFFICE

Date started 7/26/95, 19_____
 Date completed 7/27/95, 19_____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>3000</u>	<u>3</u>	<u>3hr</u>

9. WATER LEVEL
 Static water level 42' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Shen Drilling Inc Contractor
 Address 20 599 Contractor
25 - NV 89435
 Nevada contractor's license number issued by the State Contractor's Board 0081641
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 15676
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7/28/95