246-3571

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48225
Permit No.
Basin 103

NOTICE OF INTENT NO. 216755

1. OWNER Venture Reality Thomas & Lorna Thompson
MAILING ADDRESS
ADDRESS AT WELL LOCATION 138 San Clemens Ave Mark Twain, Nev.

2. LOCATION NE ¼ ¼ Sec. 30 T 17 N/S R 22 E Storey County
PERMIT NO. N/A (Issued by Water Resources) 03-282-03 (Parcel No.) Mark Twain Unit 5 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Boulders		3	67	64
Black Shale		67	136	69
Tan Clay with Some Rock		136	197	61
Black Shale		197	260	63
Black Shale with Cracks		260	300	40

RECEIVED 95 AUG 17 PM 2:37 STATE ENGINEERS OFFICE

Date started 7-31, 19 95
Date completed 7-31, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For 2 Hours And produced 15 Gallons A min		

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	60 Feet
7 7/8 Inches	60 Feet	300 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	300

Perforations:
Type perforation Torch Cut
Size perforation 1/4 x 8 Long 8 Rows
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 255 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address PO Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-8-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627