Greenhouse Well

Greenhouse Well
WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48229
Permit No.
Basin 045

NOTICE OF INTENT NO. 32147

1. OWNER Donald Korson
MAILING ADDRESS 9190 So. Virginia St., Reno, NV 89511
ADDRESS AT WELL LOCATION Lamoille, NV Mountain View Drive

2. LOCATION NW ¼ NE ¼ Sec. 28 T. 33 N/S R. 58 E. Elko County
PERMIT NO. (Issued by Water Resources) 07-080-BF-8 (Parcel No.) Tract of Land (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Gravel & Boulders		1	43	42
Brown Clay		43	45	2
Sand & Gravel	X	45	110	65
Brown Clay		110	115	5
Sand & Gravel	X	115	160	45

RECEIVED
95 AUG 17 AM 10:38
STATE ENGINEERS OFFICE

Date started 8/2/ 19 95
Date completed 8/2/ 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow Test	25		3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1½	160

Perforations:
Type perforation Mill Slot
Size perforation 3/16"x3"x6 rows
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 22' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P. O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654

Signed [signature] By driller performing actual drilling on site or contractor

Date August 10, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627