WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48230
Permit No.
Basin 045

Pruitt #1

NOTICE OF INTENT NO. 30003

1. OWNER Dee Pruitt
MAILING ADDRESS 163 12th Street
Elko, NV 89801

ADDRESS AT WELL LOCATION Sunset Lane
near Lamoille, NV

2. LOCATION SW ¼ SW ¼ Sec. 13 T 33 N/S R 57 E Elko County
PERMIT NO. 281963 (Issued by Water Resources) Parcel No. (06-520-29-0) Tract of Land (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Sandy clay & gravel		2	12	10
Gravel & Boulders		12	18	16
Brown Clay		28	40	12
Sand & Gravel	X	40	120	80

RECEIVED 95 AUG 17 AM 10:38 STATE ENGINEER'S OFFICE

Date started July 31, 19 95
Date completed July 31, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
BlowTest	35		2½ hrs.

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches	0 Feet	120 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1½	120

Perforations:
Type perforation Mill Slot
Size perforation 3/16 x 3 x 6 rows
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 120 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P. O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-15-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627