WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. ~~4832~~ 48236
Permit No.
Basin 370

NOTICE OF INTENT NO. 32920

1. OWNER Larry Snyder
MAILING ADDRESS 4705 Brayton Rd.
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 4705 Brayton Rd.
Winnemucca, NV 89445

2. LOCATION ¼ SE ¼ Sec. 7 T. 35 (N) S R. 38 E. Humboldt County
PERMIT NO. (Issued by Water Resources) 10-482-10 (Parcel No.) Sonoma Heights #1 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Sandy clay w/gravel		3	14	11
Clay		14	19	5
Gravel, Cobbles				
Boulders		19	112	93
Clay		112	116	4
Volcanic Rock		116	148	32
Fractured rock				
w/clay & sand		148	170	22
Clay w/cobbles				
small sand layers		170	250	80

RECEIVED 95 AUG 17 AM 10 25 STATE ENGINEER'S OFFICE

Date started July 18, 19 95
Date completed July 22, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		3 hrs

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	250 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17.02	.250	+1	180

Perforations:
Type perforation Mill Slotted
Size perforation 3 x 1/8
From 180 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 250 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co Inc. (Contractor)
Address P O Box 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed C. E. Eple (By driller performing actual drilling on site or contractor)
Date 8-15-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627