

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 48237  
 Permit No. 089  
 Basin. 089  
 NOTICE OF INTENT NO. 32176

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

1. OWNER J. TRIJONES ADDRESS AT WELL LOCATION DIG CANYON RD OFF  
IV, NV 89451 FRANK TOWN RD  
 MAILING ADDRESS 1301 LRI CT  
 2. LOCATION SW 1/4 NE 1/4 Sec 27 T 16 N 19 E County Moac  
 PERMIT NO. 55-301-03 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DG/ALLUVIUM</u>		<u>0</u>	<u>90</u>	<u>90</u>
<u>80-90 ALTERED</u>	<u>X</u>			
<u>GRANODIORITE</u>				
<u>GRANODIORITE</u>	<u>X</u>	<u>90</u>	<u>310</u>	<u>120</u>
<u>FAULTED &amp; FRACTURED</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 310 Feet Depth Cased 310 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/2 Inches To 0 Feet 310 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>310</u>

Perforations:  
 Type perforation SAWCUT  
 Size perforation 3X 3/32 INCH  
 From 150 feet to 170 feet  
 From 190 feet to 210 feet  
 From 230 feet to 250 feet  
 From 270 feet to 290 feet  
 From 290 feet to 310 feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 105 FT  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 105 feet to 310 feet

9. WATER LEVEL  
 Static water level 251 feet below land surface  
 Artesian flow No G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature 51 °F Quality \_\_\_\_\_

Date started JUNE 20 1995  
 Date completed JUNE 30 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30+</u>		<u>8</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING, INC Contractor  
 Address 75 LEWERS CRK RD Contractor  
WASHOE VALLEY, NV 89704  
 Nevada contractor's license number issued by the State Contractor's Board 13697A  
 Nevada driller's license number issued by the Division of Water Resources, on-site driller 1759  
 Signed Joe Reisch  
 By driller performing actual drilling on site or contractor  
 Date 8/16/95

RECEIVED  
 55 AUG 18 PM 2:02  
 STATE ENGINEERS OFFICE