WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48238
Permit No.
Basin

NOTICE OF INTENT NO. 28063

1. OWNER James Compton
MAILING ADDRESS 2855 Hwy 208 Wellington NV.
ADDRESS AT WELL LOCATION Wellington Station R.V. PARK, Wellington NV. 2455 Hwy 208

2. LOCATION NE 40 ¼ SW ¼ Sec. 2 T. 10 N/S R. 23 E. Lyon County
PERMIT NO. 60037 Issued by Water Resources
10-631-07 Parcel No.
Subdivision Name

10/21/89

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Large Cobbles and Boulders		0	26	26
Sandy Clay		26	35	9
Large Cobbles and River Gravels		35	110	75
Brown Gummy Clay		110	135	25
Coarse Gravels and Large River Rock	XXX	135	200	65

RECEIVED
95 AUG 21 PM 4:01
STATE ENGINEERS OFFICE

Date started 8-6, 19 95
Date completed 8-15, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150+	25	16 HRS

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12½ Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	12.62	.188	0	200

Perforations:
Type perforation Mill Slot
Size perforation 3 X 5/32
From 120 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 125 feet to 200 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. 160+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A-1 H Pump Company Contractor
Address 5551 Hwy 50 E #3 Contractor
Carson City NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Heck
By driller performing actual drilling on site or contractor
Date 8-15-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627