WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48239
Permit No. 59109/60015
Basin 183

NOTICE OF INTENT NO. 21093

1. OWNER VOI Lynn Holt
MAILING ADDRESS Box 249 Enterprise, Ut. 84725
ADDRESS AT WELL LOCATION Lane Valley NV.

2. LOCATION NE ¼ SW ¼ Sec. 3 T. 5 N/S R. 66 E. Lincoln County
PERMIT NO. 59109 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	6	
Clay Sand gravel 60%		6	35	
Sand gravel		35	45	
Clay Sand 40%		45	78	
Sand gravel		78	91	
Clay		91	103	
Sand gravel		103	111	
Clay Sand		111	124	
Clay 30% Sand gravel		124	150	
Clay		150	172	
Sand gravel		172	185	
Clay Sand		185	192	
Sand gravel		192	197	
Clay gravel		197	300	
Clay		300	315	
gravel		315	320	
Clay gravel		320	325	
gravel		325	330	
Sand gravel & hardpan		330	360	

Date started July 14, 1995
Date completed July 15, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
28	0	360

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42	.250	18" +	360

Perforations:
Type perforation Mill
Size perforation 5/32 x 2.5
From 160 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 360 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Drilling Contractor
Address Box 18 Contractor
New Castle, Ut. 84756
Nevada contractor's license number issued by the State Contractor's Board 0031759
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1710
Signed Dale Gardner By driller performing actual drilling on site or contractor
Date July 17-95