

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 1849
 1931 LOUSETOWN RD
 RENO, NV 89511

1. OWNER TOM ROWEN ADDRESS AT WELL LOCATION 1931 LOUSETOWN RD
 MAILING ADDRESS 1931 LOUSETOWN ROAD RENO, NV 89511
 2. LOCATION NW 1/4 NW 1/4 Sec. 4 T. 17 N/S R. 21 E. STOREY County
 PERMIT NO. 03-123-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN CLAY		0	4	
PURPLE WHITE VOL ROCK WITH PURPLE BROWN CLAY & SANDS		4	43	
GRAY WHITE VOL ROCK WITH RED SPEC		43	92	
RED & GREEN VOL ROCK	92	92	120	
TD 120	115	92	120	

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 55 Feet
8 1/2 Inches 55 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1 1/2</u>	<u>120</u>

Perforations:
 Type perforation FACTORY SAWED
 Size perforation 3/32 x 3
 From 120 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 120 feet to 52 feet

9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

Date started 8-11-95, 19_____
 Date completed 8-11-95, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15+</u>		<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. PUMP & WELL SERVICE, INC. Contractor
 Address 1800 1/2 FRAZER AVENUE Contractor
SPARKS, NEVADA 89431
 Nevada contractor's license number issued by the State Contractor's Board 35387A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
 Signed Larry Welch By driller performing actual drilling on site or contractor
 Date 8-17-95

RECEIVED
 95 AUG 22 AM 10:56
 STATE ENGINEERS OFFICE