WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48244
Permit No.
Basin 179

NOTICE OF INTENT NO. 28869

1. OWNER Conrad Schaller
MAILING ADDRESS P.O. Box 994
Ely, NV 89301
ADDRESS AT WELL LOCATION 20 miles south of Ely

2. LOCATION SW ¼ NW ¼ Sec. 31 T. 14 N/S R. 64 E. White Pine County
PERMIT NO. (Issued by Water Resources) Parcel No. 4 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	15	15
Clay & Gravel		15	120	105
Decomposed Volcanics &		120		
Gravel			175	55
Clay		175	185	10
Clay & Decomposed		185		
volcanics			285	100
Decomposed Volcanics	x	285	295	10
Clay & Decomposed		295		
Volcanics			305	10
Decomposed Volcanics	x	305	368	63

Date started August 9, 19 95
Date completed August 13, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	137	1

8. WELL CONSTRUCTION
Depth Drilled 368 Feet Depth Cased 368 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	368 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	368

Perforations:
Type perforation Factory
Size perforation 1/8" x 2½" 8 rows
From 264 feet to 368 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 368 feet

9. WATER LEVEL
Static water level 223 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nv 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
Signed Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date August 14, 1995

RECEIVED 95 AUG 22 AM 10:57 STATE ENGINEERS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627