WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48245
Permit No.
Basin 178

NOTICE OF INTENT NO. 28866

1. OWNER: Todd Haley
MAILING ADDRESS: P.O. Box 150791, East Ely, NV 89315
ADDRESS AT WELL LOCATION: 8 miles north of Ely

2. LOCATION: SW ¼ NW ¼ Sec. 14 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. (Issued by Water Resources) | Parcel No. 16 | Subdivision Name: Cross Timbers

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Gravel		2	30	28
Clay & Gravel		30	40	10
Gravel		40	60	20
Clay & Gravel		60	80	20
Water Bearing Gravel	x	80	85	5
Clay & Gravel		85	95	10
Water Bearing Sand & Gravel	x	95	105	10
Clay & Gravel		105	115	10
Water Bearing Sand & Gravel	x	115	140	25
Clay & Sand		140	160	20

RECEIVED 95 AUG 22 AM 10:56 STATE ENGINEERS OFFICE

Date started: July 24, 19 95
Date completed: July 27, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
250	98	½

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	160

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	160

Perforations:
Type perforation: Factory
Size perforation: 1/8" x 2 ½" 6 rows
From 60 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal: 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level: 62 feet below land surface
Artesian flow: G.P.M. P.S.I.
Water temperature: Cold °F Quality: Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Christiansen Drilling, Inc.
Address (Contractor): 557 Ely Avenue, Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board: 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 641
Signed: Jerald O. Christiansen (By driller performing actual drilling on site or contractor)
Date: August 14, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627