

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 48251
 Permit No. _____
 Basin. 088
 NOTICE OF INTENT NO. 29236

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER John Binneweg ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 18166 16020 Mt. Rose Hwy.
Reno, NV 89511 Reno, NV 89511
 2. LOCATION SE 1/4 SE 1/4 Sec. 34 T 18N N/S R 19 E Washoe County
 PERMIT NO. 049-090-32 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand & Boulders		0	59	59
Black Granite & Quartz w/red Valcanics		59	150	91
Valcanics w/fractures	xx	150	350	200
210' a little water				
290' Circulation problems				
310' more watter				

* plugged by well log # 100471

95 JUL 27 PM 1:35

STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 350 Feet Depth Cased 350 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 350 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	1.294	.188	+1	350

Perforations:
 Type perforation Factory
 Size perforation .060 single row
 From 330 feet to 350 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 350 feet to 50 feet

9. WATER LEVEL
 Static water level 280 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MacKay Pump & Geothermal, Inc.
 Address 1600 Mt. Rose Hwy.
Reno, NV 89511
 Nevada contractor's license number 23096
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1719
 Division of Water Resources, the on-site driller
 Signed R. Binneweg
 By driller performing actual drilling on site or contractor
 Date 7-17-'95

Date started 7-6, 1995
 Date completed 7-10, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15-20		2 hours