

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32162  
16 miles south of

1. OWNER Charles Perry ADDRESS AT WELL LOCATION Elko off Lamaille Hwy  
 MAILING ADDRESS 4722 Maple Street HCR 30  
Elko, Nevada 89801 Box 80

2. LOCATION NW 1/4 SW 1/4 Sec 30 T. 33N N/S R. 57 E Elko County  
 PERMIT NO. 47118 Issued by Water Resources Parcel No. 06-52C-06-2 Tract of Land Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt clay		0	25	25
gravel		25	30	5
green clay		30	70	40
gravel		70	75	5
blue grey clay		75	160	85
fine gravel & sand	X	160	200	40
fine-med gravel & sand	X	200	280	80
brown white rock		280	300	20

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
18 Inches 0 Feet 17 Feet  
12 5/8 Inches 17 Feet 300 Feet  
 Inches Feet Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+1 1/2	300

 Perforations:  
 Type perforation mill slot  
 Size perforation 3/32" X 3" 8 row  
 From 200 feet to 280 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 300 feet

RECEIVED  
 95 AUG 11 AM 11:30  
 STATE ENGINEERS OFFICE

9. WATER LEVEL  
 Static water level 120 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Hackworth Drilling Inc Contractor  
 Address P. O. Box 850 Contractor  
Elko, Nevada 89803  
 Nevada contractor's license number issued by the State Contractor's Board 020582  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>blow</u>	<u>150+</u>		<u>3</u>

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 8-7-95