



WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 48273
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 16095

1. OWNER JoAnn Brucato ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ 771 W. Janet Lane

2. LOCATION NW 1/4 SW 1/4 Sec 33 T. 19-S N/S R. 53 E Nye County _____
 PERMIT NO. 29-832-08 Parcel No. _____ Subdivision Name Rancho Del Sol Unit: 1 Blk: 2

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------------------|--------------|------|-----|------------|
| Surface | | 0 | 4 | 4 |
| Brown clay | | 4 | 32 | 28 |
| Brown clay & caliche | | 32 | 48 | 16 |
| Brown clay | X | 48 | 67 | 19 |
| Brown clay & caliche | | 67 | 86 | 19 |
| Brown clay | | 86 | 94 | 8 |
| Brown clay & caliche | | 94 | 108 | 14 |
| Brown clay | X | 108 | 140 | 32 |

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| From | To |
|------------------|-------------------------------|
| <u>12</u> Inches | <u>0</u> Feet <u>140</u> Feet |
| _____ Inches | _____ Feet _____ Feet |
| _____ Inches | _____ Feet _____ Feet |


CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>8 5/8</u> | <u>16.94</u> | <u>.188</u> | <u>0</u> | <u>140</u> |

Perforations:
 Type perforation Torch Cut
 Size perforation 1" width 8" long
 From 100 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 140 feet



Date started August 28, 1995
 Date completed August 28, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-----------|-------------------------------|--------------|
| <u>20</u> | <u>4</u> | <u>1/2</u> |

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Jim Pike Well Drilling, LLC Contractor
 Address P.O. Box 56 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date August 25, 1995

