WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48285
Permit No.
Basin 163

NOTICE OF INTENT NO. 14679

1. OWNER EDWARD & ELSIE KOLOSAY
MAILING ADDRESS 9124 SUNDIAL DR. LAS VEGAS, NV. 89134
ADDRESS AT WELL LOCATION DOLOMITE & TETON SANDY VALLEY

2. LOCATION SW¼/NE¼ NW¼/NW¼ Sec. 22 T. 24 N/S R. 56 E. CLARK County
PERMIT NO. Issued by Water Resources | Parcel No. 580-160-124 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	8	8
CALICHIE		8	15	7
CLAY		15	25	10
CMT. SAND & GRAVEL		25	30	5
CLAY & GRAVEL		30	60	30
CMT. SAND & GRAVEL		60	70	10
CLAY & GRAVEL		70	80	10
CALICHIE		80	90	10
CMT. SAND & GRAVEL		90	120	30
CALICHIE	W.B	120	125	5
CLAY		125	135	10
CALICHIE	W.B	135	140	5
CLAY		140	160	20
CALICHIE	W.B	160	165	5
CLAY		165	175	10
CALICHIE	W.B	175	178	3
CLAY		178	180	2

DCNR/DWR Received JUL 13 1995 LAS VEGAS OFFICE

Date started 6-20, 1995
Date completed 6-26, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	180

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	180

Perforations:
Type perforation FACTORY SAW CUT
Size perforation ⅛ INCH BY 3 INCH
From 180 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 180 feet to 50 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING CO. (Contractor)
Address P.O. BOX 3505 (Contractor)
PAHRUMP NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed Donnie Brown (By driller performing actual drilling on site or contractor)
Date 6-27-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627