WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 48325
Permit No. I 049
Basin
NOTICE OF INTENT NO. 29923

1. OWNER GARY CUMMINGS
MAILING ADDRESS P.O. BOX 709
ELKO, NV 89803

ADDRESS AT WELL LOCATION
CROW + 28th

2. LOCATION SW ¼ NE ¼ Sec. 19 T. 35 N/S R. 56 E. ELKO County
PERMIT NO. (Issued by Water Resources) 36-007-01-1 (Parcel No.) MEADOW VALLEY RANCHOS 4 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| LOAM | | 0 | 2 | 2 |
| CEMENTED GRAVEL | | 2 | 158 | |
| LOOSE GRAVEL | X | 158 | 170 | |

RECEIVED
95 AUG 14 PM 2:48
STATE ENGINEERS OFFICE

Date started 7-30, 1995
Date completed 8-1, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 45+ | | 2 |

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 170 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 12.92 | .188 | +2 | 170 |
| | | | | |

Perforations:
Type perforation SLOTS
Size perforation 3/16 X 3"
From 150 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 170 feet

9. WATER LEVEL
Static water level 100' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FERTIG DRILLING (Contractor)
Address BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-8-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627