WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

T-1

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.370 and NAC 534.340

OFFICE USE ONLY
Log No. 48334
Permit No. 61157-T
Basin 212

NOTICE OF INTENT NO. 6119

1. OWNER Las Vegas International Speedway
MAILING ADDRESS 6000 n Las Vegas Blvd
Las Vegas NV 89119

ADDRESS AT WELL LOCATION 6000 N Las Vegas Blvd

2. LOCATION NW ¼ NW ¼ Sec. 25 T. 195 N/S R. 62 E. Clark County
PERMIT NO. 61157T (Issued by Water Resources) | 520230002 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary
☐ Other

6. LITHOLOGIC LAB

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	28	28
Clay/Fine sand stK		28	340	312
White Clay		340	360	20
Sandy Clay		360	460	100
Sand-Fine		460	480	20
Sandy Clay		480	550	70
10 PS-0.030		345	435	
10 3/4- 0.3125		435	460	
10PS - 0.030		460	480	
10 3/4 - 0.3125		480	470	
10 ps - 0.030		500	530	
10 3/4 - 0.3125		530	550	

DCNR/DWR Received JUL 25 1995 BY LAS VEGAS OFFICE

Date started 5-3, 1995
Date completed 5-30, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200	144"	17

8. WELL CONSTRUCTION
Total Depth 550 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
17 1/2 Inches	0 Feet	550 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4		0.3125	1	550
10 3/4		0.3125	1	252
10 PS		0.030screen	252	262
10 3/4		0.3125	262	277
10 PS		0.030screen	277	307
10 3/4		0.1325	307	3 & 5

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 Feet to 550 Feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thompson Drilling Co (Contractor)
Address 4185 W Harmon (Contractor)
Las Vegas NV 89103

Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 1987
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 290

Signed Richard K. Thompson
By driller performing actual drilling on site or contractor
Date 7-20-95

(Rev. 12-90) (O)-627