WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48347
Permit No.
Basin 162

NOTICE OF INTENT NO. 17015

1. OWNER Gary Jefferson
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4901 Laute

2. LOCATION SE ¼ NE ¼ Sec. 29 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 45-401-12 (Parcel No.) Fox Hollow (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay - Cobbles		0	29	29
Calichie		29	32	3
Clay		32	45	13
Calichie		45	47	2
Clay		47	59	15
Calichie	WB	59	62	3
Clay		62	77	15
Calichie	WB	77	79	2
Clay		79	88	9
Calichie	WB	88	92	4
Clay		92	106	14
Calichie	WB	106	109	3
Clay		109	115	
Calichie	WB	115	117	2
Clay		117	126	9
Calichie	WB	126	128	2
Clay		128	139	11
Calichie	WB	139	141	2
Clay		141	159	18
Calichie	WB	159	163	4
Clay		163	176	13
Calichie	WB	176	179	3
Clay		179	187	8
Calichie	WB	187	193	6
Clay		193	200	7

Received JUL 31 1995 LAS VEGAS OFFICE

Date started July 12, 1995
Date completed July 15, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	200

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8" x 3"
From feet to feet
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 84 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas D (By driller performing actual drilling on site or contractor)
Date 7/25/95

USE ADDITIONAL SHEETS IF NECESSARY

(3-91) (O)-627