WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48353
Permit No.
Basin
NOTICE OF INTENT NO. 16212

1. OWNER Ernie Durston
MAILING ADDRESS
ADDRESS AT WELL LOCATION: 1951 Pioche

2. LOCATION NE ¼ NE ¼ Sec. 2 T. 21S N/S R. 53 E Nye County
PERMIT NO. (Issued by Water Resources) 44-172-15 (Parcel No.) Gamebird (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
~~Clay~~		~~8~~	~~13~~	~~5~~
~~Calichie~~		~~13~~		
Clay		4	8	4
Calichie		8	13	5
Clay		13	21	8
Calichie		21	24	3
Clay		24	33	9
Calichie		33	35	2
Clay		35	43	8
Calichie		43	46	3
Clay		46	54	8
Calichie	WB	54	59	5
Clay		59	72	13
Calichie	WB	72	78	6
Clay		78	100	22
Calichie	WB	100	104	4
Clay		104	112	8
Calichie	WB	112	116	4
Clay		116	124	8
Calichie	WB	124	127	3
Clay		127	136	9
Calichie	WB	136	140	4

Date started July 5, 1995
Date completed July 8, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR Received JUL 31 1995 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 1 3/8"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR78 Box 80358 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Da
By driller performing actual drilling on site or contractor
Date 7/19/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627