

OFFICE USE ONLY
 Log No. 48373
 Permit No. 102
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26760

1. OWNER Don & Joan Pool ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 599 _____
Silver Springs, NV. 89429 5th Street
Silver Springs, Nev.
 2. LOCATION NW 1/4 NE 1/4 Sec 18 T. 17 N/S R. 25 _____ County
 PERMIT NO. 17-281-04 _____
 Issued by Water Resources Parcel No. _____ Subdivision Name Stockton #5

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>3</u>	<u>3'</u>
<u>Sand, Clay</u>		<u>3</u>	<u>7</u>	<u>4'</u>
<u>Sand fine</u>		<u>7</u>	<u>20</u>	
<u>Sand fine - coarse</u>		<u>20</u>	<u>61</u>	
<u>Sand - coarse</u>		<u>61</u>	<u>86</u>	
<u>Gravel - 3/4 min</u>		<u>86</u>	<u>87</u>	

'95 JUL 31 P1 58
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 87 Feet Depth Cased 88 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 8 7/8 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>13</u>	<u>1.88</u>	<u>81</u>	<u>87</u>

Perforations:
 Type perforation Torcon Jet
 Size perforation 3/16 x 16 x 16 1/2 in. pipe
 From 80 feet to 87 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____ Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 87 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 62 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Joe Drilling, Inc. Contractor
 Address PO 599 Contractor
SS, NV 89429
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1876
 Signed Joe Drilling
 By driller performing actual drilling on site or contractor
 Date 7/14/95

Date started 7-14-95, 19____
 Date completed 7-14-95, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>55-60</u>		<u>2 1/4 hrs</u>