

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 48375
Permit No. _____
Basin. _____
NOTICE OF INTENT NO. 32892

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER ED Trujillo ADDRESS AT WELL LOCATION _____
MAILING ADDRESS P.O. Box 911 1450 Muddy Rd.
Winnemucca, Nev 89446 Winnemucca, Nev 89445
2. LOCATION NE 1/4 NE 1/4 Sec 11 T 34 S R 37 E Pershing County
PERMIT NO. 09-070-33 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0	20	20
gravel		20	27	7
clay w/sand streaks		27	49	22
clay, sand & gravel		49	60	11
sand & gravel		60	120	60
sand & gravel		120	125	5
clay w/sand streaks		125	148	23

8. WELL CONSTRUCTION
Depth Drilled 148 Feet Depth Cased 120 Feet
HOLE DIAMETER (BIT SIZE)
From 10 Inches 0 Feet 148 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6-5/8 _____ 188 +1 119

Perforations:
Type perforation Mill slot
Size perforation 1/8 x 2" double row
From 119 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 148 feet

9. WATER LEVEL
Static water level 15' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

Date started 7-7-95, 19____
Date completed 7-7-95, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HUMBOLDT DRILLIN & PUMP CO. Contractor
Address P.O. Box 590 Contractor
Winnemucca, Nev 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1154
Signed _____
By driller performing actual drilling on site or contractor
Date 8-2-95

95 AUG-3 10:48
STATE ENGINEER