WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48392
Permit No.
Basin 162

NOTICE OF INTENT NO. 14449

1. OWNER PRUDENCIO BAUTISTA
MAILING ADDRESS PAHRUMP NEV
ADDRESS AT WELL LOCATION RANCHOS UNIT D LOT 102 MORGAN ST

2. LOCATION NE ¼ SW ¼ Sec 9 T 20 S N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 35-181-11 (Parcel No.) CAL-VEGAS (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	1
BRN CLAY		1	5	4
HARD BRN CLAY		5	11	6
BRN CLAY		11	48	37
CALICHE		48	69	21
BRN CLAY	WB	69	81	12
HARD BRN CLAY		81	93	12
BRN CLAY	WB	93	97	4
HARD BRN CLAY		97	129	32
CALICHE	WB	129	140	11

DCNR/DWR Received SEP 5 1995 LAS VEGAS OFFICE

Date started Aug 16, 1995
Date completed Aug 25, 1995

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	1'	1 hr

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	17	188	0	140

Perforations:
Type perforation Torch Cut
Size perforation ¼ x 6"
From 80 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RON NAILLON DRILLING (Contractor)
Address BOX 265 PAHRUMP NEV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 003578
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1625
Signed Ron Naillon (By driller performing actual drilling on site or contractor)
Date Aug 26 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627