WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48403
Permit No.
Basin 212

NOTICE OF INTENT NO. 16315

1. OWNER: CRAIG WALTON
MAILING ADDRESS:
ADDRESS AT WELL LOCATION: 6140 EISNER

2. LOCATION: NW ¼ SE ¼ Sec. 14 T. 19 N/S R. 60 E. CLARK County
PERMIT NO. (Issued by Water Resources) 125-14-702-013 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CLAY + CALICHE | | 0 | 100 | 100 |
| BROWN LIME. | | 100 | 110 | 10 |
| CLAY + GRAVEL. | | 110 | 210 | 100 |
| LIMESTONE | | 210 | 220 | 10 |
| CLAY + GRAVEL. | | 220 | 455 | 235 |

*GROUTED OLD WELL FROM 287' TO SURFACE.

NDWR Received AUG 30 1995 LAS VEGAS OFFICE

Date started 8-21, 1995
Date completed 8-24, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 455 Feet Depth Cased 455 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 14 3/4 Inches | 0 Feet | 60 Feet |
| 12 1/4 Inches | 60 Feet | 455 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | +1 | 455 |

Perforations:
Type perforation: FACTORY SAW.
Size perforation: 1/8 x 2 1/2
From 375 feet to 435 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 455 feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) DESERT DRILLING
Address (Contractor) 6475 GARY AVE
LAS VEGAS NV. 89139
Nevada contractor's license number issued by the State Contractor's Board 34274
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1966
Signed Timothy Couch
By driller performing actual drilling on site or contractor
Date 8-26-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627