WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48423
Permit No.
Basin 162

NOTICE OF INTENT NO. 1040

1. OWNER Richard Noonan
MAILING ADDRESS
ADDRESS AT WELL LOCATION 300 Susan Ave.

2. LOCATION SE ¼ SE ¼ Sec 25 T 19S N/S R 52 E Nye County
PERMIT NO. (Issued by Water Resources) 28-246-06 (Parcel No.) Bell Vista (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Calichie		5	9	2
Clay		9	15	6
Calichie		15	18	3
Clay		18	28	12
Calichie		28	31	3
Clay		31	47	16
Calichie		47	49	2
Clay		49	54	5
Calichie	WB	54	59	4
Clay		59	67	8
Calichie	WB	67	69	2
Clay		69	78	9
Calichie	WB	78	82	4
Clay		82	99	17
Calichie	WB	99	103	4
Clay		103	116	13
Calichie	WB	116	119	3
Clay		119	127	8
Calichie	WB	127	130	3
Clay		130	138	8
Calichie	WB	138	140	2

Date started August 8, 1995
Date completed August 10, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
SEP 1 - 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
8 Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCK 78 BOX 86358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dam
By driller performing actual drilling on site or contractor
Date 8/24/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627