WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48425
Permit No.
Basin 049

NOTICE OF INTENT NO. 32142

1. OWNER Alan Tabor
MAILING ADDRESS 113 Colonial Circle
Elko, Nevada 89801

ADDRESS AT WELL LOCATION
Royal Crest Drive

2. LOCATION NE ¼ NW ¼ Sec. 17 T 34 N N/S R 55 E Elko County
PERMIT NO. (Issued by Water Resources) 6-09F-80 (Parcel No.) Royal Crest Special Lands (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	2	2
brown clay & boulders		2	30	28
brown siltstone & gravel		30	160	130
brown siltstone & boulders		160	280	120
brown siltstone & gravel	XX	280	390	110

RECEIVED 95 AUG 14 AM 11:38 STATE ENGINEER'S OFFICE

Date started July 18, 1995
Date completed July 18, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60		3

8. WELL CONSTRUCTION
Depth Drilled 390 Feet Depth Cased 390 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	390 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	390

Perforations:
Type perforation mill slot
Size perforation 3/16 X 3" 6 row
From 360 feet to 390 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 390 feet

9. WATER LEVEL
Static water level 245 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling Inc (Contractor)
Address P O Box 850 (Contractor)
Elko, Nevada 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-1-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627