WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48438
Permit No.
Basin 092A

NOTICE OF INTENT NO. 32554

1. OWNER HAL REARDON
MAILING ADDRESS 7100 Marlin Drive
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 1220 Goldstone
Reno, Nevada 89506

2. LOCATION NE ¼ SW ¼ Sec. 30 T. 22N N/S R. 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 079-352-07 (Parcel No.) Red Rock Estates 447 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	18	17
Brown sandy clay		18	69	51
Soft zone(coarse granite sands)		69	71	2
Brown sandy clay		71	111	40
Soft zone(med coarse granite sands)		111	113	2
Brown clay		113	174	61
Soft zone(gravels and sand)	X	174	181	7
Brown clay		181	205	24
Soft zone(gravels and sand)	X	205	217	12
Brown clay		217	225	8

Date started 8-22-95, 19
Date completed 8-23-95, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	225 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	225

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 180 feet to 225 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 foot
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 225 feet

9. WATER LEVEL
Static water level 146 feet below land surface
Artesian flow G.P.M. 35 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date August 24, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627