

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23291

1. OWNER SERPA PROPERTY ADDRESS AT WELL LOCATION NW CORNER FAIRVIEW DR. AND SALIMAN RD.
 MAILING ADDRESS CARSON CITY, NV.
 2. LOCATION ADD 1/4 Sec. 20 T. 15 NS R. 20 E. CARSON County
 PERMIT NO. M/O 753 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

6. LITHOLOGIC LOG MW-1

Material	Water Strata	From	To	Thick-ness
LIGHT BROWN SILTY SAND	-	0	6	6'
LIGHT GRAY CLAYEY SAND	-	6	8 1/2	2 1/2'
RED-BROWN SILTY SAND	-	8 1/2	12	3 1/2'
LIGHT BROWN SAND	12 1/2	12	20	8'

194 JUL +8 P 1:44
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 20 Feet Depth Cased 20 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 20 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>SCH. 40</u>	<u>PVC</u>	<u>0</u>	<u>20</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 0.220"
 From 8 feet to 20 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 7'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 7 feet to 20 feet

9. WATER LEVEL
 Static water level 12.5 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature COLD °F Quality N/A

Date started 3/7 1994
 Date completed 3/7 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>N/A</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ANDRESEN EXPLORATION DRILLING Contractor
 Address 1635 BELFORD RD. RENO, NV. 89509 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0034525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6/13/94